

The Water We Drink

EBARB WWKS DIST # 1 - AIMWELL AREA

Public Water Supply ID: LA1085059

We are pleased to present to you the Annual Water Quality Report for the year 2025. This report is designed to inform you about the quality of your water and services we deliver to you every day (Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien). Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Our water source(s) are listed below:

Source Name	Source Water Type
BUYS FROM LA1085036 SABINE WD NO 1	Ground water
BUYS FROM LA1085055 SOUTH TOLEDO BEND	Surface water

Our water system also purchases water as listed below:

Buyer Name	Seller Name
LA1085036 - SABINE PARISH WATER DISTRICT 1	MANY WATER SYSTEM
LA1085059 - EBARB WWKS DIST # 1 - AIMWELL AREA	SABINE PARISH WATER DISTRICT 1

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants – including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants – which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health. We want our valued customers to be informed about their water utility. If you have any questions about this report, want to attend any scheduled meetings, or simply want to learn more about your drinking water, please contact DONALD GARCIE at 318-645-7722.

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

The Louisiana Department of Health and Hospitals - Office of Public Health routinely monitors for constituents in your drinking water according to Federal and State laws. The tables that follow show the results of our monitoring during the period of January 1st to December 31st, 2025. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/L) – one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) – picocuries per liter is a measure of the radioactivity in water.

Treatment Technique (TT) – an enforceable procedure or level of technological performance which public water systems must follow to ensure control of a contaminant.

Action level (AL) – the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum contaminant level (MCL) – the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum contaminant level goal (MCLG) – the “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG's allow for a margin of safety.

Maximum residual disinfectant level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Level 1 assessment – A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

During the period covered by this report we had the below noted violations.

Compliance Period	Analyte	Type
1/1/2025 - 1/31/2025	CHLORAMINE	INADEQUATE MIN CHLORINE RESIDUAL(GW&SW)
3/1/2025 - 3/31/2025	CHLORAMINE	RES DISINFECT CONCENTRATION (SWTR)
4/1/2025 - 4/30/2025	CHLORAMINE	RES DISINFECT CONCENTRATION (SWTR)
5/1/2025 - 5/31/2025	CHLORAMINE	RES DISINFECT CONCENTRATION (SWTR)
10/1/2025 - 10/31/2025	CHLORAMINE	INADEQUATE MIN CHLORINE RESIDUAL(GW&SW)

Our water system tested a minimum of 8 sample(s) per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to ensure control of microbial growth.

Disinfectant	Date	HighestRAA	Unit	Range	MRDL	MRDLG	Typical Source
CHLORINE	2025	1.1	ppm	0.13 - 1.85	4	4	Water additive used to control microbes

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range	Unit	MCL	MCLG	Typical Source
ARSENIC	2/3/2025	SABINE PARISH WATER DISTRICT 1	3.9	0 - 3.9	ppb	10	0	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
FLUORIDE	5/20/2025	SABINE PARISH WATER DISTRICT 1	0.1	0.1	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE-NITRITE	2/25/2025	MANY WATER SYSTEM	0.1	0 - 0.1	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Radionuclides	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	5/20/2025	1.06	0 - 1.06	pCi/l	5	0	Erosion of natural deposits
GROSS BETA PARTICLE ACTIVITY	2/25/2025	5.33	5.33	pCi/l	50	0	Decay of natural and man-made deposits.
GROSS BETA PARTICLE ACTIVITY	2/3/2025	2.87	2.67 - 2.87	pCi/l	50	0	Decay of natural and man-made deposits.

Lead and Copper	Date	90TH Percentile	Range	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2023 - 2025	0	0 - 0.5	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2023 - 2025	1	0 - 2	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	3897 CARTER'S FERRY RD	2025	24	11.5 - 30.9	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	TEXAS HWY AT WALKER LOOP	2025	21	10.1 - 27.6	ppb	60	0	By-product of drinking water disinfection
TTHM	3897 CARTER'S FERRY RD	2025	51	17.8 - 111.2	ppb	80	0	By-product of drinking water chlorination
TTHM	TEXAS HWY AT WALKER LOOP	2025	37	14.8 - 82.8	ppb	80	0	By-product of drinking water chlorination

Unresolved significant deficiencies that were identified during a survey done on the water system are shown below.

Date Identified	Facility	Code	Activity	Due Date	Description
2/7/2022	GST 1 - NEGREET TANK	200T1 01	GWR ADDRESS TT45 DEFICIENCIES	6/6/2022	LAC 51:XII.319.D.24 - System shall ensure that no critical water system component is in poor condition or defective.;
2/7/2022	GST 1 - NEGREET TANK	200T1 01	GWR APPROVED CORRECTIVE ACTION PLAN	12/6/2022	LAC 51:XII.319.D.24 - System shall ensure that no critical water system component is in poor condition or defective.;
2/7/2022	GST 1 - NEGREET TANK	200T1 01	GWR APPROVED CORRECTIVE ACTION PLAN	7/31/2023	LAC 51:XII.319.D.24 - System shall ensure that no critical water system component is in poor condition or defective.;
11/8/2023	HD TANK HWY 191	20MG 57	GWR ADDRESS TT45 DEFICIENCIES	2/26/2024	LAC 51:XII.319.D.1 and 105.A-B,D - No public water supply shall be constructed, operated or modified to the extent that the capacity, hydraulic conditions, functioning of

					<p>treatment processes, or the quality of finished water is affected, without, and except in accordance with, a permit from the state health officer. No public water supply shall be constructed or modified to the extent mentioned above except in accordance with the plans and specifications for the installation which have been approved, in advance, as a part of a permit issued by the state health officer prior to the start of construction or modification. Detailed plans and specifications for the installation for which a permit is requested shall be submitted by the Engineer of Record or the person having responsible charge of a municipally owned public water supply or by the owner of a privately owned public water supply.;</p>
11/8/2023	HD TANK HWY 191	20MG 57	GWR APPROVED CORRECTIVE ACTION PLAN	5/20/2024	<p>LAC 51:XII.319.D.1 and 105.A-B,D - No public water supply shall be constructed, operated or modified to the extent that the capacity, hydraulic conditions, functioning of treatment processes, or the quality of finished water is affected, without, and except in accordance with, a permit from the state health officer. No public water supply shall be constructed or modified to the extent mentioned above except in accordance with the plans and specifications for the installation which have been approved, in advance, as a part of a permit issued by the state health officer prior to the start of construction or modification. Detailed plans and specifications for the installation for which a permit is requested shall be submitted by the Engineer of Record or the person having responsible charge of a municipally owned public water supply or by the owner of a privately owned public water supply.;</p>

10/28/2025	HWY 191 BOOSTER PUMP FACILITY	200T1 01	GWR ADDRESS TT45 DEFICIENCIES	2/8/2026	LAC 51:XII.319.D.24 - System shall ensure that no critical water system component is in poor condition or defective.;
10/28/2025	WATER SYSTEM	20MN 15	GWR ADDRESS TT45 DEFICIENCIES	2/8/2026	LAC 51:XII.319.D.20 - System shall have a monitoring plan that includes a list of all routine compliance samples required on a daily, weekly, monthly, quarterly, and annual basis and identify the sampling location where samples are to be collected. The public water system shall revise and re-submit its monitoring plan if changes to a plant or distribution system require changes to the sampling locations or if any significant changes to the disinfection methods are made. In addition, the public water system shall update and re-submit its monitoring plan when the system's sampling requirements or protocols change.;

Source Secondary Contaminants	Water System	Collection Date	Highest Value	Range	Unit	SMCL
ALUMINUM	SABINE PARISH WATER DISTRICT 1	2/3/2025	0.05	0.02 - 0.05	MG/L	0.2
CHLORIDE	MANY WATER SYSTEM	2/25/2025	16	16	MG/L	250
CHLORIDE	SABINE PARISH WATER DISTRICT 1	5/20/2025	18	18	MG/L	250
HARDNESS, TOTAL (AS CaCO3)	MANY WATER SYSTEM	2/25/2025	17.9	17.9	MG/L	0
HARDNESS, TOTAL (AS CaCO3)	SABINE PARISH WATER DISTRICT 1	2/3/2025	39.1	33.8 - 39.1	MG/L	0
IRON	MANY WATER SYSTEM	12/19/2025	0.17	0 - 0.17	MG/L	0.3
IRON	SABINE PARISH WATER DISTRICT 1	5/20/2025	0.15	0.04 - 0.15	MG/L	0.3
MANGANESE	MANY WATER SYSTEM	12/19/2025	0.05	0 - 0.05	MG/L	0.05
PH	MANY WATER SYSTEM	2/25/2025	5.66	5.66	PH	8.5
PH	SABINE PARISH WATER DISTRICT 1	5/20/2025	7.32	6.17 - 7.32	PH	8.5
POTASSIUM	MANY WATER SYSTEM	2/25/2025	6	6	MG/L	0
POTASSIUM	SABINE PARISH WATER DISTRICT 1	2/3/2025	3.4	2.9 - 3.4	MG/L	0
SODIUM	MANY WATER SYSTEM	2/25/2025	44.1	44.1	MG/L	0
SODIUM	SABINE PARISH WATER DISTRICT 1	2/3/2025	70.4	61.2 - 70.4	MG/L	0

SULFATE	MANY WATER SYSTEM	2/25/2025	82	82	MG/L	250
SULFATE	SABINE PARISH WATER DISTRICT 1	5/20/2025	7	7	MG/L	250

+++++Environmental Protection Agency Required Health Effects Language+++++
 Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. EBARB WWKS DIST # 1 - AIMWELL AREA is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact EBARB WWKS DIST # 1 - AIMWELL AREA and GILBERTO LIMON BUS Phone: 318-645-7722. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Additional Required Health Effects Language:

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

There are no additional required health effects violation notices.

+++++
 Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers.

We at the EBARB WWKS DIST # 1 - AIMWELL AREA work around the clock to provide top quality drinking water to every tap. We ask that all our customers help us protect and conserve our water sources, which are the heart of our community, our way of life, and our children's future. Additional information on the water system can be found at www.ldh.la.gov/watergrade. Please call our office if you have questions.









Our water system grade is a B. Water system report card is included in this report. Contact us for a copy of our lead and copper service line inventory.

EBARB WWKS DIST # 1 - AIMWELL AREA

Parish: SABINE

PWSID: LA1085059

2025 Water Grade

 Federal Water Quality	<p>Points deducted for federal violations, which include Treatment Technique and Maximum Contaminant Level Violations, may pose a public health risk over an extended period of time.</p> <p style="text-align: right;">Max of 30 points</p>	<p style="text-align: center; font-size: 2em;">-0</p>
 State Water Quality	<p>Points deducted for state violations, which include no water operator, inadequate water disinfection, and boil notices and water outages, may lead to other issues of concern if not resolved.</p> <p style="text-align: right;">Max of 10 points</p>	<p style="text-align: center; font-size: 2em;">-2</p>
 Financial Sustainability	<p>Points deducted for lack of financial sustainability which can affect operations and maintenance of the water system. An effective water rate can provide for the repair, maintenance, and future replacement of infrastructure.</p> <p style="text-align: right;">Max of 10 points</p>	<p style="text-align: center; font-size: 2em;">-5</p>
 Operations & Maintenance	<p>Points deducted for operation and maintenance deficiencies noted during water system inspections, which may affect the water quality being distributed to consumers.</p> <p style="text-align: right;">Max of 15 points</p>	<p style="text-align: center; font-size: 2em;">-3</p>
 Infrastructure	<p>Points deducted for infrastructure deficiencies noted during water system inspections, which may lead to unsafe drinking water and/or water service disruption.</p> <p style="text-align: right;">Max of 20 points</p>	<p style="text-align: center; font-size: 2em;">-5</p>
 Customer Satisfaction	<p>Points deducted for customer complaints received by the water system and/or the Louisiana Department of Health, which are confirmed to be a water quality or quantity issue in the water system.</p> <p style="text-align: right;">Max of 10 points</p>	<p style="text-align: center; font-size: 2em;">-2</p>
 Secondary Contaminants	<p>Points deducted for levels of iron and/or manganese greater than the secondary maximum contaminant levels. These levels do not pose a health risk but may cause undesirable water quality issues.</p> <p style="text-align: right;">Max of 5 points</p>	<p style="text-align: center; font-size: 2em;">-0</p>
 BONUS	<p>Points granted for having an asset management plan; a storage assessment and maintenance program; well assessment & maintenance program; participation in management training; or participation in a capacity development program.</p> <p style="text-align: right;">Max of 10 points</p>	<p style="text-align: center; font-size: 2em;">+5</p>

Standard	Standard Maximum	Point Deductions	Detailed Assessment of Standards		System Deductions
Federal Water Quality	-30	5 each	Maximum contaminant level violations	0	- 0
		5 each	Treatment technique violations for Lead and Copper Rule	0	
		10	Is the system non-compliant with an administrative order?	No	
State Water Quality	-10	1 each	Chlorine violations	2	- 2
		5	Does the water system have an operator?	Yes	
		5 each	Water outages and/or boil notices	0	
Financial Sustainability	-10	5	Did the system submit an acceptable rate study or implement an adequate rate?	No	- 5
		5	Did the water system submit an acceptable audit?	Yes	
		10	Is the system under a fiscal administrator for poor financial management practices?	No	
		5	Are there other negative circumstances that affect fiscal control of the water system?	No	
Operations & Maintenance	-15	3 each	Unresolved significant deficiencies	1	- 3
Infrastructure	-20	5 each	Unresolved significant deficiencies	1	- 5
Customer Satisfaction	-10	1 each	Valid water complaints reported	2	- 2
		10	Did the system submit a water complaint log?	Yes	
Secondary Contaminants	-5	5	Manganese and/or Iron level(s) over the secondary maximum contaminant level(s)	No	- 0
Bonus	+10	5 each	Asset management plan, storage or well assessment & maintenance plan, participation in capacity development or management training	1	+ 5
				Total Deductions + Bonus	-12
				Score	88 / 100 = 88%